

### 3. Dimensions & Gravity point

**Fresh Air Intake Unit**

ARNU76GB8Z4  
ARNU96GB8Z4

Number	Name	Description
1	Liquid pipe connection	Unit size(76k, 96k);ø19,05
2	Gas pipe connection	Unit size(76k);ø19,05 Unit size(96k);ø22,2
3	Drain pipe connection	Unit size(76k, 96k); ø22.2
4	Power supply connection	
5	Air discharge	
6	Air suction	

(unit : mm)

**Note**

1. Unit should be installed in compliance with the installation manual in the product box.
2. Unit shall be grounded in accordance with the local regulations or applicable national codes.

⊕ Gravity point

76, Seongsan-dong, Changwon City, Gyeongnam,  
641-713, Korea

CHASSIS CODE: B8

